

Hamburg, den 17. Jan. 2005  
2310 ru  
Akte: 8237 BL W

## Affirmation

### subject:

- WH 1 A diesel tank lining system, german approval no. Z-65.30-216
- WH 1 B gasoline tank lining system, german approval no. Z-65.30-140

### manufacturer:

W + H Tankschutz GmbH  
Industriestrasse 9 c  
34260 Kaufungen

We herewith confirm, that the lining systems WH 1A and WH 1B comply with the European standard EN 13160. The system corresponds with class I (highest class) of leak detection systems according to EN 13160-1, Nr. 3.



Russnak  
Technical expert  
of TÜV Nord GmbH  
test center for leak detection devices



Sitz der Gesellschaft  
TÜV NORD GmbH  
Am TÜV 1  
30519 Hannover  
Tel.: 0511 986-0  
Fax: 0511 986-1237  
hannover@tuev-nord.de  
www.tuev-nord.de

Geschäftsführung  
Dr. rer. nat. Klaus-D. Röker (Vorsitzender)  
Dipl.-Ing. Volker Drube  
Dr. rer. nat. Klaus Kleinerherbers  
Dipl.-Ing. Volker Klosowski  
Dr. rer. pol. Elmar Legge  
Klaus Orth  
Dr.-Ing. Guido Rettig  
Dipl.-Kfm. Holger Sievers  
Prof. Dr.-Ing. Claus Wolff

Vorsitzender des Aufsichtsrates  
Dr. rer. nat. Georg Schöning  
  
Amtsgericht Hannover  
HRB Nr 61566  
USt.-Id.Nr.: DE 234039777  
Steuer-Nr.: 25/207/01433

Deutsche Bank AG, Hannover  
BLZ: 250 700 70  
Konto-Nr.: 0162867 00  
SWIFT-Code: DEUTDE2H  
IBAN-Code: DE 56 2507 0070 0016 2867 00